

Amvic Fastener load Testing

Test procedures:

ASTM E2634-10 Standard Specifications for Flat Wall Insulated Concrete Forms.
 ASTM D1761-06, Standard Test for Mechanical fasteners in wood.

Type of Fastener	Allowable Lateral Fastener Load (lbs.)	Allowable withdrawal Fastener Load (lbs.)
#6 fine thread drywall screw	39.9	22
#6 coarse thread drywall screw	43.4	24.1
#8 coarse thread drywall screw	63.1	22.7
#8 deck screw	52	25.7

